



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received

Code

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title N1102.5 Maximum fenestration U-factor		Page 471
Proponent William Fox / IBA	Title Code Committee Member	
Address 6125 W 29 th Place, Speedway, IN. 46224		Phone 317-291-7575
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Add a section as follows:</p> <p>N1102.5 Maximum fenestration U-factor. The area-weighted average maximum fenestration U-factor permitted using trade-offs from Section N1102.1.3 shall be 0.48 in zones 4 and 5 for vertical fenestration and 0.75 in zones 4 and 5 for skylights.</p>		
REASON AND FISCAL IMPACT		
<p>This proposed code change would replace 52.3.11-09 approved by block vote on 12/3/09 as it mistakenly included language on SHGC.</p> <p>This is a necessary change brought to the IRC from the 2009 IECC.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		